



Village of Streamwood

Public Accessibility and Public Right-of-Way Transition Plans

February, 2021

Public Accessibility Transition Plan

Introduction

The Village of Streamwood (Village) is dedicated to ensuring and protecting the rights of all persons in compliance with the Americans with Disabilities Act (ADA) and does not discriminate in the provision of its services, programs, and activities. The Village's public buildings are considered a Village service. Improved building accessibility provides benefits not only for persons with disabilities, but for the community as a whole. This document, which will serve as the Village's Public Accessibility Transition Plan (Transition Plan), has been prepared in accordance with ADA requirements in an effort to improve the Village's existing Public Accessibility.

Purpose

The federal legislation known as the ADA, enacted in 1990 and amended in 2009, provides comprehensive civil rights protections to qualified persons with disabilities from discrimination on the basis of disability. Title II of the ADA prohibits discrimination in all services, programs, and activities provided to persons with disabilities by State and local governments. Local public agencies (LPAs) with more than 50 full- or part-time employees are required to perform self-evaluations of their current facilities relative to the accessibility requirements of the ADA and then establish a plan to correct any deficiencies. A self-evaluation is also required by Section 504 of the Rehabilitation Act for all entities receiving federal financial assistance, including federal highway aid for transportation projects. The process of self-evaluation for accessibility provides a framework for communities to develop Transition Plans that identifies barriers, prioritizes actions to address barriers, and sets forth a schedule to implement those actions.

The Transition Plan used to implement compliance must include the following elements:

- Designate officials responsible for implementation
- Provide public notice and opportunity for public participation
- Develop a grievance procedure
- Adopt design standards and guidelines
- Prepare a self-evaluation
- Schedule and budget for improvements to achieve compliance
- Monitor progress

ADA Coordinator

LPAs must designate at least one responsible employee to coordinate ADA compliance for the Village.

The Village will designate one individual to serve as the APA Coordinator. The ADA Coordinator will be responsible for directing all aspects of ADA compliance found within this Transition Plan. The ADA Coordinator will be required to be familiar with the Village's operation, properly trained in ADA building and other requirements, and able to communicate effectively with governmental agencies, advocacy groups, and the public. The Village will also designate a Public Right-of-Way ADA Coordinator in addition to the ADA Coordinator to address issues associated with the Village's public rights-of-way. Any comments, additions, suggestions, or complaints about this Transition Plan, or the Right-of-Way Transition Plan, may be directed to either the ADA Coordinator or the Public Right-of-Way ADA Coordinator as follows:

ADA Coordinator

John Peterson
Community Development Director
301 E. Irving Park Road
Streamwood, IL 60107
630-736-3800

Public Right-of-Way ADA Coordinator

Alex Riegler
Assistant Village Engineer
565 S. Bartlett Road
Streamwood, IL 60107
630-736-3850

Public Notice

LPA's must give the public an opportunity to provide input on any Transition Plans prior to adoption. The proposed ADA Transition Plans will be presented at one Public Meeting minimum and on the Village's website to allow opportunity for comments.

Grievance Procedure

The Village's currently adopted Grievance Procedure is presented within this Transition Plan for ease of reference:

This Grievance Procedure is established to meet the requirements of the Americans with Disabilities Act of 1990 ("ADA"). It may be used by anyone who wishes to file a complaint alleging discrimination on the basis of disability in the provision of services, activities, programs, or benefits by the Village of Streamwood. The Village's Personnel Policy governs employment-related complaints of disability discrimination.

The complaint should be in writing and contain information about the alleged discrimination such as name, address, phone number of complainant and location, date, and description of the problem. Alternative means of filing complaints, such as personal interviews or a tape recording of the complaint will be made available for persons with disabilities upon request.

The complaint should be submitted by the grievant and/or his/her designee as soon as possible but no later than 60 calendar days after the alleged violation to:

*John Peterson, ADA Coordinator and Community Development Director
301 E. Irving Park Road
Streamwood, IL 60107*

Within 15 calendar days after receipt of the complaint, ADA Coordinator or his designee will meet with the complainant to discuss the complaint and the possible resolutions. Within 15 calendar days of the meeting, ADA Coordinator or his designee will respond in writing, and where appropriate, in a format accessible to the complainant, such as large print, Braille, or audio tape. The response will explain the position of the Village of Streamwood and offer options for substantive resolution of the complaint.

If the response by ADA Coordinator or his designee does not satisfactorily resolve the issue, the complainant and/or his/her designee may appeal the decision within 15 calendar days after receipt of the response to the Village Manager or his designee.

Within 15 calendar days after receipt of the appeal, the Village Manager or his designee will meet with the complainant to discuss the complaint and possible resolutions. Within 15 calendar days after the meeting, the Village Manager or his designee will respond in writing, and, where appropriate, in a format accessible to the complainant, with a final resolution of the complaint.

All written complaints received by ADA Coordinator or his designee, appeals to the Village Manager or his designee, and responses from these two offices will be retained by the Village of Streamwood for at least three years.

This Grievance Procedure will be utilized for all persons wishing to file a complaint alleging discrimination within Village's Public Accessibility. For all complaints within the public right-of-way, the ADA Coordinator will notify the Public Right-of-Way ADA Coordinator to ensure that all requirements of this Transition Plan are followed in the resolution of the complaint.

Design Standards and Guidelines

The Village has adopted the following standards to apply to and govern all proposed improvements with regard to ADA compliance:

- 2010 ADA Standards for Accessible Design
- 2018 Illinois Accessibility Code

Together, these design standards and guidelines will be referred to as 'ADA Standards'.

Self-Evaluation

The first step in the Village's self-evaluation was to conduct an inventory of existing public facilities

which it either owns, maintains, or operates. Each facility was then examined to determine whether potential barriers to accessibility existed. The barrier identification process within the public buildings adopted by this Transition Plan is a two-tiered system which includes a Preliminary Evaluation and a Detailed Evaluation.

Preliminary Evaluation

As part of the Preliminary Evaluation, existing Village facilities were examined by conducting an inspection of each of the facilities. Each facility was inspected and any deficiencies noted and a possible correction outlined. We also hired an architectural firm to conduct a space needs analysis in 2018. The analysis also identified and noted any areas where improvements were required to meet ADA guidelines.

The Public Facility inventory and Preliminary Evaluation data will be updated each year by the ADA Coordinator. Results of the initial Preliminary Evaluation, which took place in 2019, are included in the **Cost and Schedule for Improvements** section.

Detailed Evaluation

All Village public facilities are included in each year's Facility Equipment Replacement Program (FERF) and will be examined in detail to determine their compliance with ADA Standards. The detailed evaluation will include a visual inspection and all physical measurements necessary to determine compliance.

Recommendations will be made and incorporated into the FERF Plan for specific improvements to correct ADA deficiencies.

Addressing Barriers

The Preliminary Evaluation provides a list of 'Non-Compliant' facilities. This list will be consulted when planning for improvements or other capital improvement projects as budget allows.

All public facilities graded as 'Non-Compliant' by a Detailed Evaluation will be brought to compliance as necessary as part of the project for which they were inspected.

Cost and Schedule for Improvements

The Village's self-evaluation for public facilities was completed in 2019. The evaluation found a total of 37 non-compliant items within the Villages public facilities, with the remainder being potentially compliant. It is important to note that additional items may be found as each of the facilities is renovated. The estimated cost to bring all 37 items into compliance is approximately \$12 million.

The list of items is included in Exhibit A.

The Village of Streamwood will make reasonable efforts to improve the accessibility of its public facilities on an ongoing basis. As funds allow, special projects with funding specifically for public facility accessibility improvements will be considered.

Monitoring of Progress

In order to be effective, the Public Accessibility Transition Plan needs to be utilized in planning and funding decisions. Therefore, it is important to update the Plan regularly to reflect changes in real world conditions and to address any possible new areas of non-compliance. Regular updates will also result in the monitoring of compliance and of the effectiveness of the plan itself. The Village intends for the ADA Coordinator to record all public facility inspections and improvements over a calendar year and to update the self-evaluation at the end of each year.

The Village of Streamwood intends to implement this Plan effective immediately from the date of this document. The Village is committed to acting on the guidelines set forth in this Plan and to actively revising and amending the Plan as progress is made.

Public Right-of-Way Accessibility Transition Plan

Introduction

The Village of Streamwood (Village) is dedicated to ensuring and protecting the rights of all persons in compliance with the Americans with Disabilities Act (ADA) and does not discriminate in the provision of its services, programs, and activities. The pedestrian system within the Village's public right-of-way is considered a Village service. Improved pedestrian accessibility provides benefits not only for persons with disabilities, but for the community as a whole. This document, which will serve as the Village's Public Right-of-Way Accessibility Transition Plan (Right-of-Way Transition Plan), has been prepared in accordance with ADA requirements in an effort to improve the Village's existing pedestrian system.

Purpose

The federal legislation known as the ADA, enacted in 1990 and amended in 2009, provides comprehensive civil rights protections to qualified persons with disabilities from discrimination on the basis of disability. Title II of the ADA prohibits discrimination in all services, programs, and activities provided to persons with disabilities by State and local governments. Local public agencies (LPAs) with more than 50 full- or part-time employees are required to perform self-evaluations of their current facilities relative to the accessibility requirements of the ADA and then establish a plan to correct any deficiencies. A self-evaluation is also required by Section 504 of the Rehabilitation Act for all entities receiving federal financial assistance, including federal highway aid for transportation projects. The process of self-evaluation for accessibility provides a framework for communities to develop a Transition Plan that identifies barriers, prioritizes actions to address barriers, and sets forth a schedule to implement those actions.

The Transition Plan used to implement compliance must include the following elements:

- Designate officials responsible for implementation
- Provide public notice and opportunity for public participation
- Develop a grievance procedure
- Adopt design standards and guidelines
- Prepare a self-evaluation
- Schedule and budget for improvements to achieve compliance
- Monitor progress

ADA Coordinator

LPAs must designate at least one responsible employee to coordinate ADA compliance for public rights-of-way. The Village will designate a Public Right-of-Way ADA Coordinator in addition to the ADA Coordinator. The Public Right-of-Way ADA Coordinator will be required to be familiar with the Village’s operation, properly trained in ADA public right-of-way requirements, and able to communicate effectively with governmental agencies, advocacy groups, and the public. The Public Right-of-Way ADA Coordinator will be responsible for directing all aspects of ADA compliance found within this Transition Plan. Any comments, additions, suggestions, or complaints about the Transition Plan may be directed to either the ADA Coordinator or the Public Right-of-Way ADA Coordinator as follows:

ADA Coordinator

John Peterson
Community Development Director
301 E. Irving Park Road
Streamwood, IL 60107
630-736-3800

Public Right-of-Way ADA Coordinator

Alex Riegler
Assistant Village Engineer
565 S. Bartlett Road
Streamwood, IL 60107
630-736-3850

Public Notice

LPAs must give the public an opportunity to provide input on the Transition Plan prior to adoption. The proposed ADA Transition Plan will be presented at one Public Meeting minimum and on the Village’s website to allow opportunity for comments.

Grievance Procedure

The Village’s currently adopted Grievance Procedure is presented within this Transition Plan for ease of reference:

This Grievance Procedure is established to meet the requirements of the Americans with Disabilities Act of 1990 ("ADA"). It may be used by anyone who wishes to file a complaint alleging discrimination on the basis of disability in the provision of services, activities, programs, or benefits by the Village of Streamwood. The Village’s Personnel Policy governs employment-related complaints of disability discrimination.

The complaint should be in writing and contain information about the alleged discrimination such as name, address, phone number of complainant and location, date, and description of the problem. Alternative means of filing complaints, such as personal interviews or a tape recording of the complaint, will be made available for persons with disabilities upon request.

The complaint should be submitted by the grievant and/or his/her designee as soon as possible but no later than 60 calendar days after the alleged violation to:

*John Peterson
ADA Coordinator and Community Development Director
301 E. Irving Park Road
Streamwood, IL 60107*

Within 15 calendar days after receipt of the complaint, John Peterson or his designee will meet with the complainant to discuss the complaint and the possible resolutions. Within 15 calendar days of the meeting, John Peterson or his designee will respond in writing, and where appropriate, in a format accessible to the complainant, such as large print, Braille, or audio tape. The response will explain the position of the Village of Streamwood and offer options for substantive resolution of the complaint.

If the response by John Peterson or his designee does not satisfactorily resolve the issue, the complainant and/or his/her designee may appeal the decision within 15 calendar days after receipt of the response to the Village Manager or his designee.

Within 15 calendar days after receipt of the appeal, the Village Manager or his designee will meet with the complainant to discuss the complaint and possible resolutions. Within 15 calendar days after the meeting, the Village Manager or his designee will respond in writing, and, where appropriate, in a format accessible to the complainant, with a final resolution of the complaint.

All written complaints received by John Peterson or his designee, appeals to the Village Manager or his designee, and responses from these two offices will be retained by the Village of Streamwood for at least three years.

This Grievance Procedure will be utilized for all persons wishing to file a complaint alleging discrimination within the Village's public right-of-way. For all complaints within the public right-of-way, the ADA Coordinator will notify the Public Right-of-Way ADA Coordinator to ensure that all requirements of this Transition Plan are followed in the resolution of the complaint.

Design Standards and Guidelines

The Village has adopted the following standards to apply to and govern all proposed improvements with regard to ADA compliance:

- 2010 ADA Standards for Accessible Design
- Draft version of the Accessibility Guidelines for Pedestrian Facilities in the Public Right-of-Way (PROWAG) as prepared by the United States Access Board
- Standard Specifications for Road and Bridge Construction in Illinois, current edition as prepared by the Illinois Department of Transportation (IDOT)
- Chapter 41 of the IDOT Bureau of Local Roads and Streets Manual

- Chapter 58 of the IDOT Bureau of Design and Environment Manual

Together, these design standards and guidelines will be referred to as ‘ADA Standards’.

Self-Evaluation

The first step in the Village’s self-evaluation was to conduct an inventory of existing pedestrian facilities and Village facilities which it either owns, maintains, or operates. Each facility was then examined to determine whether potential barriers to accessibility existed. The barrier identification process in the public right-of-way adopted by this Transition Plan is a two-tiered system which includes a Preliminary Evaluation and a Detailed Evaluation.

Preliminary Evaluation

As part of the Preliminary Evaluation, existing Village pedestrian facilities were examined using the latest available aerial photography and graded either ‘Non-Compliant’ or ‘Potentially Compliant’. Items which result in a ‘Non-Compliant’ grade include curb ramps with barrier curb, curb ramps without color-contrasting detectable warnings, curb ramps without a clear landing, and sidewalk with obvious slope deficiencies. If compliance based on these factors could not be determined by aerial photography, the facility was instead inspected as part of a windshield survey.

The pedestrian facility inventory and Preliminary Evaluation data will be updated each year by the Public Right-of-Way ADA Coordinator. Results of the initial Preliminary Evaluation, which took place in 2018, are included in the **Cost and Schedule for Improvements** section.

For the Village owned facilities we hired an architectural firm in 2018 to conduct a Space Needs Analysis and also to help us identify any deficiencies with accessibility within our public buildings. This analysis made specific recommendations which were identified with a cost and a time frame for implementation. The evaluation is available under Exhibit A.

Detailed Evaluation

All Village pedestrian facilities included in each year’s Road Program will be examined in detail to determine their compliance with ADA Standards and graded either ‘Non-Compliant’ or ‘Compliant’. The detailed evaluation will include a visual inspection and all physical measurements necessary to determine compliance (e.g., running slopes, cross slopes, width).

The Village’s Road Program includes the reconstruction or resurfacing of approximately 6 miles of roadway each year. On average, each Village roadway will be altered every 15 years as part of this

program.

In addition to Road Program roadways, the Village will perform Detailed Evaluations for all pedestrian facilities included in any additional capital improvement projects. The Village will also perform a Detailed Evaluation on any pedestrian facility for which it has received a complaint per the Grievance Procedure section of this Transition Plan.

Addressing Barriers

The Preliminary Evaluation provides a list of 'Non-Compliant' facilities. This list will be consulted when planning for future alterations as part of the Road Program or other capital improvement projects as budget allows.

All curb ramps and other pedestrian facilities graded as 'Non-Compliant' by a Detailed Evaluation will be brought to compliance as necessary as part of the project for which they were inspected. 'Non-Compliant' pedestrian facilities which are not curb ramps and which require significant curb and gutter replacement to achieve compliance will only be considered to be replaced when the street being altered is being reconstructed.

Cost and Schedule for Improvements

The Village's self-evaluation was completed in 2018. The evaluation found a total of 3,046 curb ramps within the Village, with 616 being non-compliant and the remainder being potentially compliant. It is important to note that a significant portion of the potentially compliant curb ramps may be found to be non-compliant based on a detailed evaluation. The estimated cost to bring all 616 non-compliant curb ramps into compliance is \$650,000.

The Village of Streamwood will make reasonable efforts to improve the accessibility of pedestrian facilities in the public right-of-way through the annual Road Program as well as any additional capital improvement projects. As funds allow, special projects with funding specifically for pedestrian accessibility improvements will be considered.

Additionally, given the breadth of the program and the size of the Village's pedestrian network, the Village will follow the concept of Program Access under Title II of the ADA. Program Access does not necessarily require a public entity to make each of its existing facilities accessible to and usable by individuals with disabilities, as long as the program as a whole is accessible. The Village may choose to not install a sidewalk at some locations or to lower their priority if a reasonable path of travel is available without a sidewalk.

Monitoring of Progress

In order to be effective, the Public Right-of-Way Accessibility Transition Plan needs to be utilized in planning and funding decisions. Therefore, it is important to update the Plan regularly to reflect changes in real world conditions and to address any possible new areas of non-compliance. Regular updates will also result in the monitoring of compliance and of the effectiveness of the plan itself. The Village intends for the Public Right-of-Way ADA Coordinator to record all pedestrian facility inspections and improvements over a calendar year and to update the self-evaluation at the end of each year.

The Village of Streamwood intends to implement this Plan effective immediately from the date of this document. The Village is committed to acting on the guidelines set forth in this Plan and to actively revising and amending the Plan as progress is made.

EXHIBIT A

Village of Streamwood Public Building Inventory (February 2021)

Location			Deficiency		Correction		Criteria (High Med Low)					Finalized Actions	
Reference	Facility Name	Area	Description	Barrier	ADAAG / IAC Reference	Recommended Correction	Primary (Overall)	Public Access	Frequency of use	Photo #	Estimated Cost	Finalized Correction	Date to be Corrected
VH-1	Village Hall	Atrium / Hallway	Fire Extinguishers	Fire Extinguishers are not at the correct mounting heights	IAC 400.310.a10	Relocate extinguishers to be at the appropriate height	M	M	M		\$1,000	Fire Extinguishers were relocated	1/1/2020
VH-2	Village Hall	Employee entrance	Accessible exit path	West entrance is not accessible having a 7 inch step	ADA-206.4	Raise walkway to eliminate step, also lengthen path to meet grade requirements	H	L	H		\$50,000	Walkway was raised and extended	1/1/2020
VH-3	Village Hall	Finance Counter	Service counter	Counter height exceeds 34 inches	IAC 606.3	Lower portion of counter to 34 inches	H	H	H		\$50,000	Followed recommended correction	1/1/2020
VH-4	Village Hall	CD Counter	Service counter	Counter height exceeds 34 inches	IAC 606.3	Lower portion of counter to 34 inches	H	H	H		\$20,000	Followed recommended correction	1/1/2020
VH-5	Village Hall	Trustee Conf Rm	Sink access	Wing wall in the way of sink	IAC 606.2	Remove the wall	M	L	M		\$10,000	Followed recommended correction	1/1/2020
VH-6	Village Hall	Public Bathrooms	Access to door	18" of clear floor space is required on pull side of doors	IAC 202.5.3.2	Enlarge opening to doors to provide clear space.	H	H	H		\$25,000	Followed recommended correction	1/1/2020
VH-7	Village Hall	Trustee Restroom	Water Closet access	Water Closet is too close to wall	ADA- 4.16.2	Move water closet so the centerline of water closet must be 18 inches from wall	M	L	M		\$20,000	Followed recommended correction	1/1/2020
VH-8	Village Hall	Council Chambers	Dias access	There is a step to access the dais from the rear	ADA-203.9	Add ramp in place of step to access dais area	L	L	L		\$15,000	Followed recommended correction	1/1/2020
VH-9	Village Hall	Entrance Doors	Automatic Door operators	South and West doors do not have handicap assist doors	ADA-207	Provide power assist to entrance doors	H	H	H		\$25,000	Followed recommended correction	1/1/2020
VH-10	Village Hall	Fire Alarm	Alarm system throughout building	Existing alarm system does not meet all the height and location requirements	ADA 215	Upgrade or replace fire alarm system to meet requirements	H	H	H		\$50,000	Followed recommended correction	1/1/2020
VH-11	Village Hall	Lower Level Restroom	Grab Bars Missing	Existing restroom does not have grab bars	ADA- 4.16.2	Add grab bars to restrooms	H	H	H		\$1,000	Followed recommended correction	3/1/2021
PW-1	Public Works	Men's restroom	Urinal Access	Urinal too close to wall	IAC 606.2	Move urinal to provide side access, also lower urinal to meet requirements	H	M	H		\$20,000	Followed recommended correction	1/1/2020
PW-2	Public Works	PW Counter	Service counter	Counter height exceeds 34 inches	IAC 606.3	Lower portion of counter to 34 inches	H	H	H		\$20,000	Followed recommended correction	1/1/2020
PW-3	Public Works	Lobby	Drinking Fountain	Drinking Fountain not accessible	ADA-211	Replace drinking fountain with an accessible model	H	H	H		\$10,000	Followed recommended correction	1/1/2020
PW-4	Public Works	Entrance Doors	Automatic Door operators	North door do not have handicap assist door	ADA-207	Provide power assist to entrance doors	H	H	H		\$25,000	Followed recommended correction	1/1/2020
PW-5	Public Works	Doors to office area	Access to door	18" of clear floor space is required on pull side of doors	IAC 202.5.3.2	Enlarge opening to doors to provide clear space.	H	H	H		\$12,000	Followed recommended correction	1/1/2020
PW-6	Public Works	Center Stair	Access between floors	No accessible path between first floor and second floor	ADA-203.9	Add elevator to allow access between floors	H	L	H		\$60,000	Followed recommended correction	9/1/2021
PW-7	Public Works	Entrance	Public Access	Sidewalk grade slope to main entry.	ADA-206.4	Lengthen path to meet grade requirements	H	L	H		\$50,000	Followed recommended correction	9/1/2021
PW-8	Public Works	Break Room	Employee Access	Accessible counter and appliances	IAC 606.3	Install accessible counter and appliances	H	L	H		\$60,000	Followed recommended correction	9/1/2021

Location			Deficiency		Correction		Criteria (High Med Low)					Finalized Actions	
Reference	Facility Name	Area	Description	Barrier	ADAAG / IAC Reference	Recommended Correction	Primary (Overall)	Public Access	Frequency of use	Photo #	Estimated Cost	Finalized Correction	Date to be Corrected
PW-9	Public Works	Crew Areas	Employee Access	Accessible counter and appliances	IAC 606.3	Install accessible counter and appliances	H	L	H		\$30,000	Followed recommended correction	9/1/2021
PW-10	Public Works	Patio Area	Employee Access	No accessible path to exterior lunch area	ADA-206.4	Accessible patio break area for employee lunch.	H	L	H		\$30,000	Followed recommended correction	9/1/2021
PW_11	Public Works	Lockers	Employee Access	Accessible lockers in locker room in lower level.	IAC 606.3	Accessible lockers in locker room in lower level.	H	L	H		\$30,000	Followed recommended correction	9/1/2021
PW-12	Public Works	Mechanics Area	Employee Access	No Accessible stair to mezzanine	IAC 606.3	Renovation of existing stair into an accessible stair to existing mezzanine	H	L	H		\$100,000	Followed recommended correction	3/1/2022
PW-13	Public Works	Mechanics Area	Employee Access	No accessible path to supervisor's office.	ADA-206.4	Moving existing office from mezzanine to main level with full accessible access	H	L	H		\$100,000	Followed recommended correction	3/1/2022
PW_14	Public Works	Mechanics Area	Employee Access	No accessible toilet room	IAC 606.3	Creation of a new accessible toilet room.	H	L	H		\$130,000	Followed recommended correction	3/1/2022
FS-31	Fire Station 31	Second Floor	Employee Access	No accessible path between first floor and second floor	ADA-206.4	Replace two story structure with a one-story accessible structure	H	L	H		\$10,000,000	Followed recommended correction	3/1/2022
FS-32	Fire Station 32	Kitchen	Employee Access	No accessible sink in kitchen	IAC 606.3	Addition of an accessible sink in the kitchen.	H	L	H		\$10,000	Followed recommended correction	3/1/2022
FS-32	Fire Station 32	Toilet Room	Employee Access	No accessible toilet/shower rooms	ADA-206.4	Creation of new accessible toilet/shower rooms with accessible fixtures and changing bench.	H	L	H		\$50,000	Followed recommended correction	3/1/2022
FS-32	Fire Station 32	Toilet Room	Employee Access	No accessible toilet room	IAC 606.3	Creation of a new accessible bay toilet room.	H	L	H		\$50,000	Followed recommended correction	3/1/2022
FS-32	Fire Station 32	Patio	Employee Access	No accessible path to the patio	ADA-206.4	Changing access to exterior patio with an accessible door access.	H	L	H		\$20,000	Followed recommended correction	3/1/2022
FS-33	Fire Station 33	Kitchen	Employee Access	No accessible sink in kitchen	IAC 606.3	Addition of an accessible sink in the kitchen.	H	L	H		\$10,000	Followed recommended correction	3/1/2022
FS-33	Fire Station 33	Toilet Room	Employee Access	No accessible toilet/shower rooms	IAC 606.3	Creation of new accessible toilet/shower rooms with accessible fixtures and changing bench.	H	L	H		\$50,000	Followed recommended correction	3/1/2022
FS-33	Fire Station 33	Toilet Room	Employee Access	No accessible toilet room	IAC 606.3	Creation of a new accessible bay toilet room.	H	L	H		\$100,000	Followed recommended correction	3/1/2022
FS-33	Fire Station 33	Patio	Employee Access	No accessible path to the patio	ADA-206.4	Changing access to exterior patio with an accessible door access.	H	L	H		\$20,000	Followed recommended correction	3/1/2022
FS-33	Fire Station 33	Main Entry	Employee Access	No accessible main entry	ADA-206.4	Renovation of main entry to provide accessible access.	H	L	H		\$50,000	Followed recommended correction	3/1/2022
FS-33	Fire Station 33	Drinking Fountain	Employee Access	No accessible drinking fountain	IAC 606.3	Addition of accessible drinking fountain.	H	L	H		\$10,000	Followed recommended correction	3/1/2022
FS-33	Fire Station 33	Sidewalk	Employee Access	No accessible path to the main entry	ADA-206.4	Correct grading for accessible sidewalk at main entry from Accessible parking spaces.	H	L	H		\$80,000	Followed recommended correction	3/1/2022